

# Declaration of conformity

regarding the determination of energetic efficiency  
according to EN 13141-7:2010

Flair 325 4/0 R EU ENTHALPIE  
ducted ventilation unit  
Tested unit

**Brink Climate Systems B.V.**  
Client


**KF.82.01.257.BD.02**  
Document number

**Europäisches Testzentrum für  
Wohnungslüftungsgeräte (TZWL) e.V.**  
Test laboratory

**Heat recovery  
Efficiency**  
Keywords


**Dortmund, 2018-11-29**  
Date and place of issue

Signature



**T. Özbiyik**  
Head of test laboratory

This declaration comprises of 2 pages.



🏠 TZWL e. V.  
Ernst-Mehlich Str. 4a  
44141 Dortmund

✉ info@tzwl.de

☎ +49 (0)231 53477-0

☎ +49 (0)231 53477-109

🌐 www.tzwl.de

👥 managing board  
chairman Dr.-Ing. M. Gringel  
co-chairman Dipl.-Ing. (FH) T. Özbiyik  
co-chairman Prof. Dr.-Ing. U. Hahn  
Dipl.-Bew. (FH) J. Köntopp

🇩🇪 seat of the association  
Dortmund, registered at  
Amtsgericht Dortmund,  
register ID VR 5236  
tax ID 317 5940 3514  
VAT ID DE 2094 29304

📄 The reproduction of single parts of  
this document and the usage of this  
document for advertising purposes  
requires written evidence of TZWL e. V.

The test results solely refer to the  
denoted serial number

## Declaration of conformity regarding the determination of energetic efficiency according to EN 13141-7:2010

On behalf of Brink Climate Systems B.V. the determination of energetic efficiency was conducted by Europäisches Testzentrum für Wohnungslüftungsgeräte (TZWL) e. V. in Dortmund, Germany.

Tests were carried out according to:

- EN 13141-7:2010; Ventilation for buildings - Performance testing of components/products for residential ventilation - Part 7: Performance testing of a mechanical supply and exhaust ventilation units (including heat recovery) for mechanical ventilation systems intended for single family dwellings

Technical data of the tested unit:

|                       |                              |
|-----------------------|------------------------------|
| Manufacturer:         | Brink Climate Systems B.V.   |
| Type:                 | Flair 325 4/0 R EU ENTHALPIE |
| Serial Number:        | 430013181502                 |
| Year of construction: | 2018                         |
| Power supply:         | 230 V ~ 50 Hz                |
| CE-Label:             | Yes                          |
| Maximum volume flow:  | 325 m <sup>3</sup> /h        |

Results, energetic efficiency 7°C:

| Air flow<br>[m <sup>3</sup> /h] | Temperature ratio,<br>supply air $\eta_{\theta,su}$<br>[%] | Humidity ratio<br>supply air $\eta_{X,su}$<br>[%] | Total electric power<br>consumption $P_E$<br>[W] | Specific electric<br>power consumption<br>[W/m <sup>3</sup> /h] |
|---------------------------------|--|---|--|---|
| 51                              | 96,0   | 79,1  | 11,6   | 0,23  |
| 226                             | 83,2   | 57,1  | 32,2   | 0,14  |
| 328                             | 76,3   | 38,2  | 79,3   | 0,24  |

Results, energetic efficiency 2°C:

| Air flow<br>[m <sup>3</sup> /h] | Temperature ratio,<br>supply air $\eta_{\theta,su}$<br>[%] | Humidity ratio<br>supply air $\eta_{X,su}$<br>[%] | Total electric power<br>consumption $P_E$<br>[W] | Specific electric<br>power consumption<br>[W/m <sup>3</sup> /h] |
|---------------------------------|--|---|--|---|
| 50                              | 93,2   | 80,3  | 11,7   | 0,23  |
| 225                             | 80,4   | 62,3  | 35,0   | 0,15  |
| 326                             | 76,8   | 57,5  | 79,9   | 0,24  |

Results of performance tests of aerodynamic characteristics, of heat recovery characteristics and of the effective power consumption are taken from tests with number M.82.01.257.BD.rev01